



Canadian Food Inspection Agency Agence canadienne
d'inspection des aliments

Food Safety Directorate
3851 Fallowfield Road
Ottawa, Ontario, Canada
K2H 8P9

Tel: (613) 228-6698
Fax: (613) 228-6675

Date: 2008/09/10

File:# I226

Mr. Robert N. Maley
Vice President
IG Creative Solutions Inc.
23697 Regency Park Drive
Warren, Michigan
48089 U.S.A.

RE: Zip-Up Ceilings and Zip-Up UnderDeck

This will acknowledge your submission, concerning the above wall/ceiling systems for which you are requesting acceptance for use in food plants.

Based on the present available information no objection will be taken to the installation of said walls systems in food plants provided that:


- 1- All joints are to be sealed with an acceptable flexible caulking compound to provide a smooth, flush and impervious joint;
- 2- All corners and wall-floor junctions shall be covered.

Should any changes occur in the composition or intended use of the aforementioned wall systems, then this acceptance will be considered **null and void**.

Should any unacceptable sanitary maintenance problems occur as a result of improper installation or maintenance, the inspection service may request corrective action to be taken.

This acceptance should not be misconstrued as an endorsement for these or similar wall systems and their use in food plants will depend upon their continued acceptability to all concerned.

Yours truly,


Bernard Dallaire
Acting Program Officer
Chemical Evaluation
Food Safety Division
Food Safety Directorate
BD/jc